

Existing Public Restrooms have 7'-11.5" ceiling height. Existing Locker rooms have 7'-5.5" ceiling height. and the single toilet currently has a 7'-5" ceiling height. New ceiling heights to be same.

Underside of 8" concrete plank roof structure is sloping 1/8" in 12" in the restroom areas.

The existing section (from 1985) shows the High point is approximately, 9'-6+-" above finished floor and Low point is 9'-2"+- aff.

Plank height above floor to be field verified.

REFERENCE SHEET:

REFERENCE ADDENDUM:2

REFERENCE RFI:

REFERENCE SUPPLEMENTAL INFORMATION:

REFERENCE CHANGE ORDER PROPOSAL REQUEST:

REFERENCE SUBMITTAL:

NEI ENENGE GOBINI I AL.				
TSKP	JOB NAME / NUMBER: GHTD-PUBLIC RESTROOM RENOVATIONS		TITLE: -PLANK ROOF SECTION	DRAWING NO:
STUDIO One Hartford Square West	SCALE:			SKA-02
146 Wyllys Street, Bldg 1-203 Hartford, CT 06106 • 860,547,1970	DATE: 06/18/20	PREPARED BY:		010102